## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

## FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

**LISTING No.** 7167-0085:175 Page 1 of 1

CATEGORY: Control Units (Household)

LISTEE: ADT Security Systems, 4128 North Freeway Blvd, Sacramento, CA 95834

Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942\*

**DESIGN:** Model SAFEWATCH PLUS RF Residential fire alarm control unit. Refer to listee's data sheet

for additional detailed product description and operational considerations. System

components:

487250 CPU-Main Control Unit 487541 CPU-Main Control Unit 487270 Wireless Touchpad 487244 Wireless Touchpad

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL Inc. Label

**APPROVAL:** Listed as residential RF type, fire alarm control unit for use with separately listed compatible

initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation

Manual for details.

**NOTE:** Burglary and other non-fires functions were not examined. Refer to listee's data sheet for

compatibility of non-fire alarm devices.

**XLF**: 7167-1126:111

\*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 8, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager